

OZNAKA UZORKA: Hrmotine , sirova voda
Godišnje izvješće, 2017.god.

| PARAMETAR | MJERNA JEDINICA | UKUPNI BROJ MJERENJA | MDK | MIN. | MAX. | χ | NED: |
|---------------------------------|---------------------|----------------------|------------------------|-------|-------|--------|------|
| BOJA | °PtCo | 241 | 20 | 5,5 | 83 | 22,56 | 107 |
| TEMP. VODE | °C | 242 | 25 | 3,5 | 18,5 | 11,41 | 0 |
| TEMP. ZRAK | °C | 41 | - | -11 | 26 | 10,90 | 0 |
| MUTNOĆA | NTU | 242 | 4 | 0,604 | 5,624 | 2,91 | 4 |
| MIRIS | | 220 | bez | 0 | 0 | 0 | |
| ELEKTROVO. | µS/cm | 242 | 2500 | 302 | 447 | 361 | 0 |
| pH | | 242 | 6,5 -9,5 | 6,6 | 8,27 | 7,59 | 0 |
| SAC | | 240 | Bez značajnih promjena | 0,639 | 9,37 | 3,40 | |
| UTROŠAK KMnO₄ | mg/L O ₂ | 51 | 5 | 0,9 | 3,7 | 1,93 | 0 |
| AMONIJ | mg/L | 58 | 0,5 | 0 | 0,8 | 0,015 | 1 |
| NITRITI | mg/L | 50 | 0,5 | 0 | 0,04 | 0,0077 | 0 |
| NITRATI | mg/L | 49 | 50 | 0,3 | 2,51 | 1,36 | 0 |
| KLORIDI | mg/l | 48 | 250 | 1,6 | 6,8 | 3,79 | 0 |
| ALUMINIJ | µg/L | 37 | 200 | 0 | 60 | 3,91 | 0 |
| KOLI.BAK. | B/100ml | 51 | 0 | 2 | 276 | 51,68 | 51 |
| FEK.KOLI. | B/100ml | 51 | 0 | 0 | 131 | 14,40 | 48 |
| FEK.STREP. | B/100ml | 50 | 0 | 0 | 230 | 16,82 | 48 |
| CLOST.PERF R | B/100ml | 49 | 0 | 0 | 25 | 1,51 | 28 |
| PSEUDM.AER. | B/100ml | 32 | 0 | 0 | 23 | 3,89 | 18 |
| UBB 37 °C | B/1ml | 50 | 20 | 5 | 2140 | 298,92 | 46 |
| UBB 22 °C | B/1ml | 47 | 100 | 672 | 2240 | 735,01 | 46 |